

Results AgBB Assessment Elastopor H 1622/2 (spray foam)

- No carcinogens were found after 3 and after 28 days
- The Total VOC ("TVOC") was significantly below 10,000 µg/m³ after 3 days
- The Total VOC ("TVOC") was significantly below 1,000 µg/m³ after 28 days
- The Total SVOC was significantly below 100 µg/m³ after 3 and after 28 days
- The LCI (NIK) rating R for the measured VOC single substances with more than 5 µg/m³

The tested product **Elastopor H 1622/2** is appropriate for use indoors according to the AgBB Guidance in its version of June 2002.

(See attached file: BING_FACTSHEET08_Indoor Air261005.doc)

Elastogran



BASF Group